



Ward Water Inc. & Ward Plumbing Inc.
PO Box 201 Steep Falls, Maine 04085

Office: 207-675-3272

Mobile: 207-329-3154

Email: office@wardwater.com

Web: www.wardwater.com

Well Chlorination

***Caution water contains high levels of chlorine
Water can be used for flushing.***

The following steps will prepare the water for retest:

1. Do not use excessive water until _____
2. After _____ start flushing well using outside faucet and hose.
3. Do not run chlorinated water near plants or trees
4. Run water out hose as much as possible without running well dry
5. Example: run 30 minutes let set for 1 hour, run 30 minutes, etc.
6. This process can take one to two days depending on well depth and well flow
7. When you can no longer smell or taste bleach coming from the hose you are ready for the next step.
8. Run all cold faucets inside house until there is no smell or taste.
9. Run all hot faucets inside house until there is no smell or taste, this can take longer if you have a water heater
10. Draw one inch of water in a clear glass. Then using the provided silver packets pour small amount of power inside packet into glass
11. Swirl glass around to mix. If you do not see any pink color pour rest of packet into glass and swirl
12. If no pink color develops call for retest
13. If pink water is present water needs to be run more.
14. Any questions call 329-3154